

# DECLARATION OF CONFORMITY



## Manufacture's Name:

Kidde-Fenwal Inc.  
400 Main Street  
Ashland, Ma 01721

## Declared Conformity:

Kidde-Fenwal, Inc declares that the products listed below comply with the protection requirements of Directives: *2014/30/EC (EMC); 2014/35/EC (LVD); 2002/95/EC Rohs*. Validation included compliance with the listed standards. Testing was performed by an independent test laboratory and the results are documented within Intertek Verification Report No. 10229475BOX-001

## Standards:

IEC 60947-1 Edition 5.1: 2011-03: Low Voltage Switchgear and Control gear – General Rules  
IEC 60947-5-1: Edition 3: 2003 + A1:2009: Low Voltage Switchgear and Control gear Part 5-1: Control Devices and Switching Elements – Electromechanical control Circuit Devices.  
IEC 60947-5-1: 2004; A1:2009: Low Voltage Switchgear and Control gear Part 5-1: Control Devices and Switching Elements – Electromechanical control Circuit Devices

## Product:

### Over Heat Detectors:

#### **Horizontal DAF Units:**

12-X27020-000, 12-X27020-001: 125VAC 5A, 125VDC 0.5A  
12-X27021-000, 12-X27021-001: 125VAC 5A, 125VDC 0.5A, 24VDC 2A, 49VDC 1A

#### **Vertical DAF Units:**

12-X27120-000, 12-X27120-022: 125VAC 5A, 125VDC 0.5A  
12-X27121-000, 12-X27121-020: 125VAC 5A, 125VDC 0.5A, 24VDC 2A, 48VDC 1A  
12-200001-00X: 125VAC 5A, 125VDC 0.5A, 24VDC 2A, 48VDC 1A  
12-X28020-003: 125VAC, 5A, 125VDC, 0.5A  
12-X28021-005: 125VAC, 5A, 125VDC, 0.5A, 24 VDC 2A, 48 VDC 1A.

The technical documentation required to demonstrate that the products meet the requirements of the stated directives have been compiled. The CE mark was first applied in November 2015.

Name: Paul Finn  
Title: Certification Engineer  
Place & Date of Issue: Ashland, MA, USA, 11 January 2018

Signature: *Paul Finn*