



UIRV.E19310 Heat-automatic Fire Detectors for Use in Hazardous Locations

[Page Bottom](#)

Heat-automatic Fire Detectors for Use in Hazardous Locations

[See General Information for Heat-automatic Fire Detectors for Use in Hazardous Locations](#)

KIDDE-FENWAL INC
400 Main St
Ashland, MA 01721-2150 USA

E19310

Class I, Groups A, B, C and D; Class II, Groups E, F and G.

Type Detector	Type No.	Temp Range F	Spacing Ft	
			Smooth Ceiling	to Wall or Partition
Rate compensation	27121-000	*	50	25
Rate compensation	27121-000	**	25	12.5
Rate compensation	27121-020 12-F27121-12060 12-F27121-13060	*	50	25
Rate compensation	27121-020	**	25	12.5
Rate compensation	28021-000	*	50	25
Rate compensation	28021-000	**	25	12.5
Rate compensation	28021-005 TF-E28021-005	*	50	25
Rate compensation	28021-005	**	25	12.5
Rate compensation	28021-011, -012, -013	**	25	12.5

*-140-144, 175-194, 250-269, 325-344, 400-424.

**-145-164, 195-234, 270-309, 345-384, 425-474.

Electrical ratings: 5 amp, 125 v, ac; 0.5 amp, 125 v, dc; 2.0 amp, 24 v, dc; 1.0 amp, 48 v, dc.

This Listing applies to heat detectors only and not to wiring or other appliances of systems of which they form a part.

[Last Updated](#) on 2011-11-01

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".